

**GENERAL NOTES**

1. LOCATE UNDERGROUND UTILITIES PRIOR TO DIGGING. CALL USA (UNDERGROUND SERVICE ALERT) 1-800-277-2600, MON THRU FRI 6AM TO 7PM, A MINIMUM 2 WORKING DAYS WITH A MAXIMUM 14 CALENDAR DAYS, TO OBTAIN A TICKET. CONTACT THE DISTRICT INSPECTOR OR PARK SUPERVISOR FOR DISTRICT UTILITIES NOT LOCATED BY USA.
2. POSTS SHALL BE 6X6 PRESSURE TREATED ROUGH DOUGLAS FIR #2 OR BETTER FREE OF HEART CENTER. PRESSURE TREATMENT SHALL BE AWPA CA-B 0.21 PCF OR ACQ 0.40 PCF MINIMUM.
3. SET POSTS PLUMB AND BACKFILL WITH NATIVE MATERIAL. REMOVE ALL ROCKS AND CLOUDS GREATER THAN 1.5" THEN COMPACT IN 6" LIFTS.
4. ONE RAIL FENCE RAILS SHALL BE 4X6 NON-PRESSURE TREATED, S4S DOUGLAS FIR, #2 OR BETTER.
5. TWO RAIL FENCE RAILS SHALL BE 2X8 NON-PRESSURE TREATED, S4S DOUGLAS FIR, #2 OR BETTER.
6. INSTALL FENCE RAILS FACING TRAIL, UNLESS NOTED OTHERWISE.
7. CARRIAGE BOLTS SHALL BE 3/8" DIA HOT-DIPPED GALVANIZED CARRIAGE BOLTS WITH NUTS AND FLAT WASHERS. COUNTERSINK NUTS AND WASHERS AT BACK OF POSTS WITH 1.125" DIA X 1" MAX DEEP HOLES. PROJECTING BOLT ENDS SHALL BE CUT FLUSH WITH POST AFTER TIGHTENING.
8. STRUCTURAL SCREWS SHALL BE SELF-DRILLING, RUGGED STRUCTURAL SCREWS "RSS", WITH "CLIMATEK" COATING, AS MANUFACTURED BY GRK CANADA LTD, OR EQUAL. USE 3/8 x 7-1/4" FOR ONE-RAIL FENCE AND 5/16 x 4" FOR TWO-RAIL FENCE. SCREW HEADS SHALL BE INSTALLED FLUSH OR SLIGHTLY COUNTER-SUNK PER MFG.
9. INSTALL CARRIAGE BOLTS OR STRUCTURAL SCREWS CENTERED ON AND PERPENDICULAR TO MEMBERS WITH AN EVEN AND EQUIDISTANT PATTERN.
10. EASE EXPOSED CORNERS OF POSTS AND RAILS AT THE END OF ALL FENCES, INCLUDING BOTH SIDES OF EACH FENCE OPENING.
11. STAIN RAILS AND POSTS "EBRPD BROWN STAIN" PER STD PLAN 003 PAINT SPECIFICATIONS.



**WOOD FENCES GENERAL NOTES**

DRAWN	CR	KEY	REVISIONS	DATE	APPROVED
CHECKED	AS		ORIGINAL ISSUE	12-04-15	
OPERATIONS	DC				ROB LIM, PE, CHIEF OF DESIGN & CONSTRUCTION
					DATE 12/8/15

STD PLAN

**201**

SHEET 1 OF 1  
NOT TO SCALE