

# Chabot Gun Club (CGC) Stormwater Pollution Prevention Plan (SWPPP) Evaluation and Development of Concept Proposals for Lead Removal from Stormwater

## DISTRICT'S RESPONSE TO REQUEST FOR INFORMATION

1. Is it possible to get a copy of the current SWPPP for the Chabot Fun Club and or a site plan that shows the current and types of BMPs?  
The Chabot Gun Club SWPPP and facility map have been posted on the District's website under the RFP section.
2. What is the budgeted ballpark amount for this contract?  
The District is requesting proposals from qualified firms that will insure compliance with State Water Board regulations while operating the Chabot Gun Club. The District has budgeted the funds necessary to retain the firm that best meets the District's needs.
3. Does the SWPPP need to be completed before July 1, 2015?  
Yes, the revised SWPPP should be completed prior to July 1, 2015, so the facility can be enrolled in the new Industrial General Permit (IGP).
4. Does the District have storm water sampling analysis for lead?  
Yes, stormwater sampling results are available and will be provided to the proposer selected.
5. Does it exceed the Industrial General Permit baseline limit that is 0.262 mg/L annual average?  
Yes, some of the samples have exceeded IGP baseline limit for lead.
6. Could the District release information mentioned in item 2 and 3 under the PARK DISTRICT RESPONSIBILITIES now?  
The District will provide this information to the proposer that is selected during the RFP process.
7. What is the Gun Club data from 2009 mentioned in 2.c. and 3.b. under the PARK DISTRICT RESPONSIBILITIES in the RFP?  
The results of stormwater runoff analysis including results for total and dissolved lead from the facility.
8. Please advise if there is a need for a professional engineer to stamp and certify the task 2 deliverables.  
The plans developed under Task 2 will only be concept designs and do not require a professional engineer's stamp; however, it is strongly encouraged for a professional engineer to assist with the development and design of potential control methods.
9. Does Task 1 also include training for the new SWPPP through the services of Trainer of Record, who will be the CASQA/SWRCB as soon as it is rolled out in March 2015?  
Task 1 does not include training for the new SWPPP.

10. We would like to team up with potential proposers or bidders for the subject RFP. Do you have a list of these consultants?

The District will consider proposals from project teams, although we will not assist with the formation of teams in order to maintain the integrity of the RFP process. The District will not release the names of proposers until all proposals have been received.