


# Keller Beach Water Quality Status



**LOW RISK**

## WATER MEETS STATE STANDARDS

Beach is open. Weekly testing for bacteria is within the state health standards. However, there is always some risk with beach water contact. Beach water contact may cause illness. Do not swallow water. Shower and towel dry after water contact. Water quality conditions can change at any time.

For more information, contact the East Bay Regional Park District (510) 544-2328

**RIESGO BAJO**

## EL AGUA CUMPLE CON LAS NORMAS ESTATALES

La playa está abierta. Las pruebas semanales de bacterias en el agua cumplen las normas estatales de salud. Sin embargo, siempre hay cierto riesgo al entrar en contacto con el agua de la playa. El contacto con el agua de la playa puede provocar enfermedades. No trague el agua. Báñese y séquese con una toalla después de haber estado en contacto con el agua. La calidad del agua puede cambiar en cualquier momento.

Para más información, contacte el East Bay Regional Park District (510) 544-2328

 EAST BAY REGIONAL PARK DISTRICT

Current Condition = **Green Light** (Beach is Open. Low Health Risk)  
**DO NOT SWIM IN BAY FOR UP TO 3 DAYS AFTER RAINSTORM**

### Water Quality “Stop Light” Designations:

**Red Light:** Beach is Closed. No swimming, wading or water contact. There is a Water Quality Hazard.

**Yellow Light:** Beach is Open. There is an increased health risk for swimming and wading. Bacteria results do NOT meet the State Health Standards.

**Green Light:** Beach is Open. Low health risk for water contact. Bacteria results are within the State Health Standard Limits.

### \*Current Site Conditions

DATE	NORTH BEACH <b>Low Risk- Green Light</b>			SOUTH BEACH <b>Low Risk- Green Light</b>		
	Total Coliforms	Fecal Coliforms	Entero	Total Coliforms	Fecal Coliforms	Entero
<b>February 10th</b>	<b>200</b>	<b>11</b>	<b>15</b>	<b>190</b>	<b>11</b>	<b>22</b>
January 27th	10	1	7	10	< 1	1
January 15th	52	2	7	No Sample	No Sample	No Sample
January 13th	220	15	<b>500</b>	86	3	18

### State Water Quality Bacteria Levels:

Daily Maximum Level: Total Coliforms: 10,000, Fecal Coliforms: 400, Enterococcus: 104

All results expressed as bacterial density (Colony Forming Units or Most Probable Number) per 100 mL

FOR FURTHER INFORMATION CONTACT THE EAST BAY REGIONAL PARK DISTRICT  
 WATER MANAGEMENT DEPARTMENT AT: (510) 544-2328

\* To ensure you are viewing the most current version of the Water Quality Conditions Test Results PDF file please refresh your screen.